



TYLER PIPE SUGGESTED SPECIFICATIONS

Tyler Pipe • 11910 CR 492 • Tyler, TX 75706 • (800) 527-8478

Suggested Specifications

BELOW GRADE

ALL cast iron drain, waste, vent, sewer, and storm lines shall conform to the requirements of CISPI Standard 301, ASTM A 888 or ASTM A 74. Pipe and fittings shall be marked with the collective trademark of the Cast Iron Soil Pipe Institute and be listed by NSF International.

ABOVE GRADE

ALL cast iron drain, waste, vent, sewer, and storm lines shall conform to the requirements of CISPI Standard 301, ASTM A 888 or ASTM A74. Pipe and fittings shall be marked with the collective trademark of the Cast Iron Soil Pipe Institute and be listed by NSF International.

JOINTS

- No-Hub Couplings shall conform to the CISPI 310, Standard and ASTM A 1277 and be listed by NSF International.
- Heavy-Duty Couplings shall conform to the requirements of ASTM C 1540.
- Compression Gaskets for Hub & Spigot shall conform to the requirements of ASTM Standard C 564 and ASTM C 1563.
- Joints for pipe and fittings shall conform to the manufacturer's installation instructions and local code requirements.
- Most current edition

For more information, please contact:

McWanePlumbingTechServices.com

TylerPipe.com • 800-527-8478